230 Crescent Avenue Chelsea, Ma.

Report of Analysis



NO. 6 FUEL OIL/BUNKER FUEL

Lab Reference	2005-0364	Classification	Sh. Tk - 1
Vessel/Barge	EKTORAS	Grade	No. 6 Fuel Oil
Client	Sprague Energy	Terminal	Sprague-Searsport, ME
Date on Sample	12.27.2005	Sampled by	Keith
Date Tested	12.27.2005	Tested by	RG/JM
Allocations	ICB-Portland, ME	Lab Overtime	Yes

Tests	Method	Results	Unit of Measure
API Gravity @ 60°F	D-4052	16.5	API
Flash Point, PMCC	D-93B	180	Degrees F
Pour Point/Upper	D-97	12/54	Degrees C/F
Sulfur Content	D-4294	0.473	Weight %
S&W Content	D-1796	0.10	Volume %
Viscosity	D-445	403.8	eSt
Viscosity @ 122F	D-2161	190.6	SFS
Ash Content	D-482	0.046	Weight %
Heat of Combustion	D-240	18,842	Btu/lb
Gravity	Table 8	7.962	lb./gal
Heat of Combustion	D-240	150,020	Btu/Gal.
Nitrogen	D-5762	0.35	Weight %
Vanadium	D5863B	15	Ppm
Sodium	D5863B	17	Ppm
Water by Distillation	D-95	0.10	Volume %
Sediment by Extraction	D-473	0.04	Weight %
Asphaltenes	IP-143/D-3279	2.2	Weight %
Conradson Carbon Residue	D-189	10.5	Weight %

Approved: Rafael Garcia

SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHORE TANK AS NOTED ON THE CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED FOR ANY OTHER PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PRODUCT AFTER DELIVERY BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS MAY BE SPECIFICALLY SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE BETWEEN SPRAGUE AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO LIABILITY FOR CLAIMS OR LOSSES THAT MAY ARISE FROM CUSTOMER'S USE OF THIS INSPECTION REPORT/ANALYSIS.